



OFFICE OF THE DEPUTY FIRE OFFICER  
CUTTACK CIRCLE  
BUXI BAZAR, CUTTACK 753001

FORM-V  
FIRE SAFETY CERTIFICATE

(See rule-13(3) of the Odisha Fire Prevention and fire safety Rules, 2017r/w Odisha Fire Prevention and fire safety (Amendment) Rules,2019)

File No.C-170-2022

Certificate No. 152 /CR/CTC

Dated : 28.10.2022

This Certificate is valid up to 27/10/2024  
(Apply for renewal at least three months before expiry)


Certified that the Gurukul Public School (G + 2 floors), situated over plot no.111/113,Khata No.20 At/Po-Haridaspur, Ps-Dharmasala, Dist-Jajpur was re-inspected by Officer of the Fire service on 23.08.2022 in presence of Sri Abhaya Kumar Jena with team and it has been found to comply with the Fire prevention and safety requirements in accordance with Odisha Fire Prevention and Fire Safety Rules 2017. Further in pursuance of Govt. of Odisha Fire Prevention and Fire Safety Rules-2017 read with Fire prevention and Fire Safety (Amendment),Rules-2019 and Odisha Fire Service one time relaxation scheme published wide Govt. of Odisha Home Department Notification No.28550/CD, Bhubaneswar, dt 28.08.2020 and that its various floors are fit for occupancy or usage as noted hereunder against each subject to compliance to the conditions as prescribed herein below:-

01	Ground + 1 <sup>st</sup> Floor + 2 <sup>nd</sup> floor	--- Usage ---	Educational (school)
----	--	---------------	-------------------------

**CONDITIONS:-**

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises should be maintained by the occupier(s) in best repairs and efficient working condition all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed obstructed or modified in any way.
3. The occupier (s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire Drills/rehearsals should be organized at least once in six months by involving local fire station.
5. Photocopies of the Certificate should be framed and displayed at all conspicuous places in all lobbies/ corridors in all floors of building/premises.
6. The plan needs to be regularized /approved by the competent plan approving authority of the jurisdiction as per Govt of Odisha Home Department notification No. 28550/CD, Bhubaneswar, dt 28.08.2020 regarding one time relaxation scheme for Odisha Fire Service on requirement of structural Fire Safety parameters.
7. All other conditions furnished in Odisha Fire Service one time relaxation scheme published vide Govt of Odisha Home Department Notification No. 28550/CD, Bhubaneswar, dt 28.08.2020 will be applicable to this occupancy and applicant will comply on each point accordingly.
8. The Fire Safety Certificate do not absolve provisions made in any others rules and will not automatically immure the provisions made therein.

By order of the Director of Fire service


  
 (Trilok Kumar Babu)  
 Deputy Fire Officer  
 Cuttack Circle, Cuttack

Name & Designation of the Issuing Officer:- Trilok Kumar Babu,Deputy Fire Officer

Memo No. 153 /CR.CTC

Date

Copy to the Principal,Gurukul Public School,At/Po-Haridaspur, Ps-Dharmasala, Dist-Jajpur for information and necessary action from your end.

  
 Deputy Fire Officer  
 Cuttack Circle, Cuttack